

कार्यालय कनिष्ठ अभियन्ता जन स्वास्थ्य अभियांत्रिकी विभाग, अनुभाग  
पलसाना, सीकर (राज.)

S.N. - 173

Date 30/01/2024

जल संबन्धी प्रमाण-पत्र

प्रमाणित किया जाता है कि एस०बी०पी० शिक्षण एवं अनुसंधान संस्थान पलसाना सीकर के भू जल का परीक्षण किया गया। यह जल पीने के लिये उपयुक्त है।

Principal  
J.S.B.P. Institute of Education & Research  
Palasana, Sikar (Raj.)

  
30/01/2024  
प्रभारी भू जल एवं जलदाय विभाग पलसाना

  
प्रभारी भू जल एवं जलदाय विभाग पलसाना



Office of the Junior Chemist  
Public Health Engineering Department, Rajasthan  
Regional Laboratory, Sikar

Report of the Chemical Examination of Water

1995  
10-1-2024

To  
Secretary,  
S.V.P. Education & Research Institution,  
V & GP, Palsana, Distt. Sikar (Raj).

Reference No : S.V.P./2024/Tes/72, Dated : 06/01/2024

Date of Receipt : 07/01/2024

District : SIKAR  
Block : PIPRALI  
Sample Taker : Sh. Dharmendra Kumar

Source	Permissible Value as per B.I.S : 10500/2012		TW
Location			SVP, Education And Research Institution.
Other Habitation			PALSANA
Village/Town			PALSANA
Gram Panchayat			PALSANA
Date of Collection	Desirable Limit	Permissible limit in absence of alternate Source	06/01/2024
Date of Examination			09/01/2024
Sample No.			1173

Note:- All results except pH are in mg/L

	6.5 to 8.5	No relaxation	7.9
pH	1	5	1
Turbidity(NTU)	5	15	Colourless
Colour	Agreeable	Agreeable	Small less
Odour	---	---	25
Temperature	200	600	90
Total Alkalinity	200	600	90
Total Hardness (as CaCO3)	75	200	20
Calcium (as Ca)	30	100	9.76
Magnesium (as Mg)	250	1000	20
Chloride(as Cl)	200	400	2
Sulphate(as SO4)	45	45	17
Nitrate as(NO3)	1.0	1.5	0.1
Fluoride	500	2000	195
Total Dissolved Solids	1.0	No Relaxation	---
Iron	0.2	1.0	---
Residual Chlorine			

Principal  
(CBSE School Code-10779)  
S.V.P. Shikshan Avam Anusandhan Sansthan  
PALSANA (Sikar) Raj.

Remarks: Water is Potable (P)/Unpotable (U)  
No Lab./Tech.(chem)/023-241773

Junior Chemist  
PHED Laboratory, Sikar


राजस्थान सरकार  
कार्यालय चिकित्सा अधिकारी प्रभारी, सामुदायिक स्वास्थ्य केन्द्र, पलसाना (सीकर)


ओडर नं. - स्पेसिया/2023-24/209


chcpalsana@gmail.com  
दिनांक:- 04/03/2024

-:- CERTIFICATE -:-

This is Certified that Health and sanitary condition of SVP Shikshan avam anusandhan sansthan has been found satisfactory and the water has been found safe for drinking.

  
डॉ. रामस्वरूप मीणा  
चिकित्सा अधिकारी  
सामु. स्वा. केन्द्र, पलसाना (सीकर)

  
Principal  
(CBSE School Code-10779)  
S.V.P. Shikshan Avam Anusandhan Sansthan  
PALSANA (Sikar) Raj.

  
सचिव  
एस. वी. पी. शिक्षण एव अनुसंधान संस्थान  
पलसाना (सीकर)

